

## **SECTION 6 IRREVERSIBLE AND IRRETRIEVABLE COMMITMENTS OF RESOURCES**

See section 6 of the DEIS.

The project will utilize 158,800 gpd of the Pine Hill WWTP's design flow of 500,000 gallons per day (gpd). The average day flows of the Pine Hill WWTP are reported at 130,000 gpd based on current operational reports. The WWTP will still have 211,700 gallons of capacity available.

There will be no loss of any old growth forests since none exist on the project site.

There will be no loss of public recreational opportunities because the project site lands are private and don't provide public recreational opportunities. Public recreational opportunities will be enhanced by the modified project via additional public skiing available at Highmount and additional public land being available at Big Indian.